



# Certificate No: EW166B



This certificate is valid for Building Regulations & associated technical guidance in force on the date of registration and for the regulations in the countries indicated

Cavitytrays Type X, Type G, Type GBOT, Advantage, Type E and Caviweep Type W

## Description of Product

Cavitytrays Type X, Type G, Type GBOT, Advantage, Type E and Caviweep Type W is a polypropylene damp proof course system for use as a damp-proof course in cavity walls with an outer leaf of brickwork or, in timber-framed constructions, with a masonry cladding or skin. It is a DPC system for use in masonry cavity wall construction or in timber wall construction where a masonry skin is being utilised.



## Key Factors Assessed

- Mechanical Resistance & Stability
- Durability serviceability and identification

## Validity

This certificate was first issued on 23<sup>rd</sup> December 2011 and is valid until 22<sup>nd</sup> March 2021  
Issue Dated 30<sup>th</sup> January 2018

## Scope of Registration

This certificate relates to a polypropylene damp proof course system for use as a damp-proof course in cavity walls with an outer leaf of brickwork or, in timber-framed constructions, with a masonry cladding or skin.

## Conditions of Certificate

For use in Cavity masonry walls or brick skins to timber framed walling.

Approval for use in cavity masonry walls and timber framing if used with proprietary strapping.

Must be installed in accordance with the manufactures instructions and specification sheets.

LABC consider that, Cavitrays Type X, Type G, Type GBOT, Advantage, Type E and Caviweep Type W, will meet the functional requirements of the Building Regulations (listed below) if the criteria detailed in this certificate are met;



### The Building Regulations 2010 (as amended) England & Wales

Regulation 7	Materials and workmanship
Note:	The product is acceptable.
AD C	Site Preparation and Resistance to Ground Moisture
Note:	The product satisfies the requirement.



### The Building Regulations 2010 (as amended) England

None presently



### The Building Regulations 2010 (as amended) Wales

None presently



### The Building (Scotland) Regulations 2004 (as amended)

If you would like to discuss a specific use of the product in Scotland it will require an additional assessment under the Scottish Building Regulations and accordingly you should contact the LABSS STAS Administrator at [www.labss.org](http://www.labss.org)

## Non-Regulatory Information



### LABC Warranty

The use of Cavitytrays Type X, Type G, Type GBOT, Advantage, Type E and Caviweep Type W has not been assessed to meet the requirements of the LABC Warranty Technical Manual. If you would like to discuss a specific use please make an enquiry to [technical.services@labcwarranty.co.uk](mailto:technical.services@labcwarranty.co.uk)

## Supporting Documentation

Cavity Trays Damp-Proofing Manual pages: 29 (Type E), 32 (Type G), 55 (type X), 63 (Advantage), 102 (Caviweep Type W)

BBA Approval ETA 03/0014 valid from 31.08.2003 to 31.08.2013, second version

Briefing note from Research Authority – Doncaster Metropolitan Borough Building Control 19.09.2011

## Contact Information

Cavity Trays Limited  
Administration Centre  
Yeovil  
Somerset  
BA22 8HU  
Tel: 01935 474769  
Email: [enquiries@cavitytrays.co.uk](mailto:enquiries@cavitytrays.co.uk)  
Web: [www.cavitytrays.co.uk](http://www.cavitytrays.co.uk)