

## RD Certificate Number: EWS671C

### Flamefast Kitchensafe fire suppression system KSC003

#### Description

This is an assessment of the Flamefast Kitchensafe KSC003 fire suppression system, which uses a low PH liquid chemical suppressant delivered via a/multiple nozzle(s) attached to the cooker extract hood and activated by thermal detection sensor to extinguish exposed cooking oil stove top fires.

#### Scope of Registration

Due to space limitations, the Registered Detail certificate should be consulted for the full scope of this registration.



#### Validity

This system has been checked for compliance in accordance with English, Welsh and Scottish Building Regulations

Registration was first issued on 27/04/16 and is valid until 27/04/19 providing there are no amendments to applicable regulations.

**Issue dated** 10/05/2018

#### Further Information

For more detailed information including access to the full certificate and supporting documents please use this link <http://www.labc.co.uk/our-services/registered-details/ews671c-flamefast-kitchensafe-fire-suppression-system-ksc003>

#### Flamefast Fire Systems Ltd

Unit 9  
Brunel Close  
Park Farm  
Wellingborough  
NN8 6QX  
Tel: 01933 420 733  
Email: [Salessouth@flamefast.co.uk](mailto:Salessouth@flamefast.co.uk)  
Web: [www.fire-systems.co.uk](http://www.fire-systems.co.uk)

